

BI-02.08 Fire suppression system is integrated into machine operation

(Accountable - Engineering Manager (Site) (Unassigned))

Expectations

Mobile equipment cannot be operated inadvertently if the fire detection and suppression system is operable e.g. isolated or has been discharged.

Specify

An acknowledgement and override is required to move mobile equipment if the fire detection and suppression system is operable e.g. isolated or has been discharged.