

BI-02.12 Serviced and checked fire extinguishers on mobile equipment

(Accountable - Engineering Manager (Site) (Unassigned))

Expectations

Portable fire extinguishers are installed on all mobile equipment.

Specify

Portable power fire extinguishers two appropriately sized portable fire-fighting extinguishers (e.g. 9 kg ABE) installed on mobile equipment.

Implement

Through acceptance inspection. Daily checks, weekly inspections and as required inversion to avoid powder compaction.

Monitor

Professional inspection to Australian Standard AS 1851 Maintenance of Fire Protection Systems and Equipment (maximum interval is six months)