

CFM-ER-01 Liquid fuel loss of containment - not considered during emergency response

Result of a fire notified to emergency responders is made worse by:

- Emergency responders not adequately considering/identifying/addressing the failure of reservoirs, hoses or lines containing fuel, hydraulics, lubrication, coolants etc.
- Responders failing to identify the potential for a subsequent catastrophic failure of liquid fuel containment fuel that ignites or explodes causing further injury and property losses.

Credible Failure mode is addressed by:

- 🛡️ BI-05.05 Combustible liquids transfer site-based standards and procedures are in place
- 🛡️ BI-05.40 Automatic notification of equipment fire to Emergency Response
- 🛡️ BI-09.01 Emergency Preparedness
- 🛡️ BI-09.03 Strategy for testing, reviewing and maintaining the currency of the emergency response plan
- 🛡️ BI-09B.01 Emergency Response Drills
- 🛡️ BI-09B.04 Emergency response team fire training